



## MECHANICAL CODE MANUAL

**MCM 610.0**

**04/01/03**

### PAINT SPRAY BOOTHS

We received an interpretation from ICBO (now ICC) stating in part that “the provisions for spray paint booths in the Fire Code should be applied rather than the provisions in the Mechanical Code.

Based on the above, we will no longer apply any of the provisions of Section 610 of the Mechanical Code to paint spray booths, including the restriction on the termination distance of exhaust outlets from property lines, but rather we will continue to require Fire Department approval for these projects and consider that approval as proof of compliance with the Fire Code.

Supercedes MCM 609 (1/96).

---

Kaveh Razavi  
Chief Mechanical Inspector

KR:et

P:\BSPUB\MECHANIC\ET\MECHANICAL CODES\MCM 610.DOC  
05/27/03